

Energy Save AW-EVI 30 – ErP Data

Appendix I Test results

Table 1.	Heating mode(Low temperature application):						P	
Model	Indoor unit: PAEVH-30V4DEA/IA; Outdoor unit: PAEVH-30V4DEA							
Product type	Air to Water	Heating season	<input checked="" type="checkbox"/>	Average	<input type="checkbox"/>	Warmer	<input type="checkbox"/>	Colder
1. Test conditions:								
Condition	Part Load Ratio in %				Outdoor heat exchanger	Indoor heat exchanger		
	Formula	A	W	C	Inlet dry (wet) bulb temperature °C	Inlet/outlet water temperatures (°C)		
A	$(-7-16)/(T_{designh}-16)$	88	N/A	N/A	-7(-8)	a / 34		
B	$(+2-16)/(T_{designh}-16)$	54	N/A	N/A	2(1)	a / 30		
C	$(+7-16)/(T_{designh}-16)$	35	N/A	N/A	7(8)	a / 27		
D	$(+12-16)/(T_{designh}-16)$	15	N/A	N/A	12(11)	a / 24		
E	$(TOL-16)/(T_{designh}-16)$				TOL	a / 35.3		
F	$(T_{bivalent}-16)/(T_{designh}-16)$				Tbiv	a / 34		
G	$(-15-16)/(T_{designh}-16)$	N/A	N/A	N/A	-15	N/A		
Remark: a) With the water flow rate as determined at the standard rating conditions given in EN14511-2 at 30/35 conditions, the capacity is 17715.33 W, the power is 4011.08W, the COP is 4.42W/W.								
2.Tested data/correction data(Average):								
General test conditions/ Part-Load	Unit	A(-7)/W34 (88%)	A2/W30 (54%)	A7/W27 (35%)	A12/W24 (15%)	A(-10)/W35.3 (100%)	A(-7)/W34 (88%)	
	--	A	B	C	D	E	F	
Data collection period	hh: min:sec	2:10:00	4:00:00	2:10:00	2:10:00	2:10:00	2:10:00	
The heat pump defrosts	--	No	Yes	No	No	No	No	
Complete Cycles	--	0	1	0	0	0	0	
Barometric pressure	kPa	101.02	101.01	101.01	101.02	101.01	101.02	
Voltage	V	397.7	398.5	398.4	398.9	397.8	397.7	
Current input of the unit	A	15.86	6.98	5.08	4.15	15.79	15.86	
Power input of the unit	kW	8.435	3.395	2.368	1.881	8.395	8.435	
Test conditions indoor unit								
Inlet Water temperature, DB	°C	27.18	25.71	23.17	19.93	29.08	27.18	
Outlet Water temperature, DB	°C	33.97	29.82	26.97	23.97	35.32	33.97	

Appendix I Test results

Test conditions outdoor unit							
Air inlet temperature, DB	°C	-7.00	2.04	7.00	12.00	-10.00	-7.00
Air inlet temperature, WB	°C	-8.11	1.05	6.00	11.00	-10.91	-8.11
Summary of the results							
Total heating capacity	kW	23.609	14.356	13.259	14.157	21.684	23.609
Effective power input	kW	8.546	3.505	2.479	1.992	8.506	8.546
Coefficient of performance (COP)	--	2.76	4.10	5.35	7.11	2.55	2.76
Compressor frequency	Hz	90	40	30	30	90	90
Water flow	m ³ /h	3.00	3.00	3.00	3.00	3.00	3.00
Remark: * In part condition, outlet temperature data is recorded by a full average complete cycle's data.							
3.Calculation/conclusion for SCOP(Average):							
Tdesignh(°C)	-10	Tbiv(°C)		-7			
Pdesignh(kW)	26.689	TOL(°C)		-10			
Test result A, B, C, D, E, F conditions:							
Condition	Part load	Measured capacity	COP at measured capacity	Cdh	CR	COP at part load	
E	26.689	21.684	2.55	0.00	1.00	2.55	
F	23.609	23.609	2.76	0.00	1.00	2.76	
A	23.609	23.609	2.76	0.00	1.00	2.76	
B	14.371	14.356	4.10	0.00	1.00	4.10	
C	9.238	13.259	5.35	0.99	0.70	5.32	
D	4.106	14.157	7.11	0.99	0.29	6.94	
CR: part load divided by capacity;							

Appendix I Test results

Electric power consumptions	Unit	Value
Thermostat-off mode [P_{TO}]	kW	0.010
Standby mode [P_{SB}]	kW	0.010
Crankcase heater [P_{CK}]	kW	0.033
Off mode [P_{OFF}]	kW	0.010
Conclusions:	Unit	Value
SCOP _{on} :	kWh/kWh	4.21
SCOP:	kWh/kWh	4.21
Q_H :	kWh/year	55139
Q_{HE} :	kWh/year	13089
$\eta_{s,h}$	%	165.5
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 2)	--	A++

Appendix I Test results

Table 2.		Heating mode(Medium temperature application):					P	
Model		Indoor unit: PAEVH-30V4DEA/IA; Outdoor unit: PAEVH-30V4DEA						
Product type		Air to Water	Heating season	<input checked="" type="checkbox"/> Average	<input type="checkbox"/> Warmer	<input type="checkbox"/> Colder		
1. Test conditions:								
Condition	Part Load Ratio in %				Outdoor heat exchanger	Indoor heat exchanger		
	Formula	A	W	C	Inlet dry (wet) bulb temperature °C	Inlet/outlet water temperatures (°C)		
A	$(-7-16)/(T_{designh}-16)$	88	N/A	N/A	-7(-8)	a / 52		
B	$(+2-16)/(T_{designh}-16)$	54	N/A	N/A	2(1)	a / 42		
C	$(+7-16)/(T_{designh}-16)$	35	N/A	N/A	7(6)	a / 36		
D	$(+12-16)/(T_{designh}-16)$	15	N/A	N/A	12(11)	a / 30		
E	$(TOL-16)/(T_{designh}-16)$				TOL	a / 55.3		
F	$(T_{bivalent}-16)/(T_{designh}-16)$				Tbiv	a / 52		
G	$(-15-16)/(T_{designh}-16)$	N/A	N/A	N/A	-15	N/A		
Remark: a) With the water flow rate as determined at the standard rating conditions given in EN14511-2 at 47/55 conditions, the capacity is 27251.16 W, the power is 10664.51W, the COP is 2.56W/W.								
2. Tested data/correction data(Average):								
General test conditions/ Part-Load	Unit	A(-7)/W52 (88%)	A2/W42 (54%)	A7/W36 (35%)	A12/W30 (15%)	A(-10)/W55.3 (100%)	A(-7)/W52 (88%)	
	--	A	B	C	D	E	F	
Data collection period	hh: min:sec	2:10:00	2:10:00	2:10:00	2:10:00	2:10:00	2:10:00	
The heat pump defrosts	--	No	No	No	No	No	No	
Complete Cycles	--	0	0	0	0	0	0	
Barometric pressure	kPa	99.85	99.85	99.85	99.80	99.75	99.85	
Voltage	V	397.9	398.4	398.6	398.7	397.8	397.9	
Current input of the unit	A	17.78	9.47	5.15	4.40	18.60	17.78	
Power input of the unit	kW	9.772	4.870	2.502	2.073	10.339	9.772	
Test conditions indoor unit								
Inlet Water temperature, DB	°C	45.65	37.62	32.57	26.17	49.29	45.65	
Outlet Water temperature, DB	°C	51.97	41.98	35.98	30.04	55.27	51.97	

Appendix I Test results

Test conditions outdoor unit							
Air inlet temperature, DB	°C	-7.01	2.02	7.00	11.97	-10.00	-7.01
Air inlet temperature, WB	°C	-7.97	1.00	6.00	10.99	-10.93	-7.97
Summary of the results							
Total heating capacity	kW	21.818	15.165	11.894	13.494	20.644	21.818
Effective power input	kW	9.895	4.993	2.625	2.198	10.462	9.895
Coefficient of performance (COP)	--	2.20	3.04	4.53	6.15	1.97	2.20
Compressor frequency	Hz	76	43	27	27	76	76
Water flow	m ³ /h	3.00	3.00	3.00	3.00	3.00	3.00
Remark: * In part condition, outlet temperature data is recorded by a full average complete cycle's data.							
3.Calculation/conclusion for SCOP(Average):							
Tdesignh(°C)	-10	Tbiv(°C)		-7			
Pdesignh(kW)	24.664	TOL(°C)		-10			
Test result A, B, C, D, E, F conditions:							
Condition	Part load	Measured capacity	COP at measured capacity	Cdh	CR	COP at part load	
E	24.664	20.644	1.97	0.00	1.00	1.97	
F	21.818	21.818	2.20	0.00	1.00	2.20	
A	21.818	21.818	2.20	0.00	1.00	2.20	
B	13.281	15.165	3.04	0.99	0.88	3.03	
C	8.538	11.894	4.53	0.99	0.72	4.51	
D	3.794	13.494	6.15	0.99	0.28	5.99	
CR: part load divided by capacity;							

Appendix I Test results

Electric power consumptions	Unit	Value
Thermostat-off mode [P_{TO}]	kW	0.010
Standby mode [P_{SB}]	kW	0.010
Crankcase heater [P_{CK}]	kW	0.033
Off mode [P_{OFF}]	kW	0.010
Conclusions:	Unit	Value
SCOP _{on} :	kWh/kWh	3.31
SCOP:	kWh/kWh	3.31
Q_H :	kWh/year	50956
Q_{HE} :	kWh/year	15401
$\eta_{s,h}$	%	129.3
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 1)	--	A++